

Sophie Butcher

From: Ann Seviour-Harte
Sent: 07 June 2016 12:47
To: Licensing Unit
Cc: Chris Woodhatch
Subject: Thirty3Hz - 16 Park Street, Guildford, Surrey, GU1 4XB - Application to vary premises licence [UNC]

Follow Up Flag: Follow up
Flag Status: Completed

Dear Licensing

I refer to the above variation application.

I object to the variation and make the following representation on the grounds of public safety:

Rear Smoking Area

There is no reference to the maximum number of persons permitted in this restricted space area.

There is reference to 'some polycarbonate' drinks containers but it is not stated in the application whether these containers will be mandatory for outside drinking.

The application states that this area will be monitored by a door supervisor or member of staff or CCTV monitored by the 'front door supervisor'. It is not clear how a 'front door supervisor' will be able to monitor the front door and view the CCTV of the rear smoking area at the same time.

Front of premises smoking area

The application states that no more than 25 patrons will be allowed in this area to smoke. This volume of people outside the premises will conflict with patrons attempting to enter and leave the premises and is likely to cause overspill towards the highway.

There is reference to 'some polycarbonate' drinks containers but it is not stated in the application whether these containers will be mandatory for outside drinking.

Late Night Refreshment

The application makes reference to late night refreshment however the premises do not have facilities to provide this. If hot food facilities were to be provided at the premises, this will have significant implications and increased risk upon fire safety and the operating schedule should reflect this increased risk.

Performance of plays

The application makes reference to the performance of plays, however the premises are not suitable for this type of entertainment. There is no reference to maximum permitted numbers for the audience or seating numbers or arrangements.

Removal of existing Conditions

The current conditions (H) relating to monitored access via the rear gate, the position of staging and electrical safety should remain as conditions unless the applicant is able to demonstrate how this public safety issues can be alternatively addressed.

I would be able to remove my objection to this variation if the applicant is able to offer suitable and sufficient methods in the operating schedule to address these public safety matters.

If you have any queries, please do not hesitate to contact me.

Mrs Ann Seviour-Harte
Occupational Health and Food Safety Officer
Health and Community Care Services
Guildford Borough Council
Millmead House
Millmead
Guildford
Surrey GU2 4BB
Tel: 01483 444386
Email: Ann.Seviour-harte@guildford.gov.uk
GCSX email: Ann.Seviour-harte@guildford.gcsx.gov.uk (for information up to RESTRICTED)
Follow us on Twitter [@GuildfordBC](https://twitter.com/GuildfordBC)

Please note that standard e-mail transmission via the Internet is not a secure means of communicating. This is because messages pass across a public computer network, which can be intercepted and read by system administrators as well as accessed by computer criminals such as hackers during the transmission between the sender and recipient. Guildford Borough Council has considered the security risks and has made arrangements to keep your information safe. If our reply to your enquiry includes confidential or personal information about you, we will encrypt it using Egress Switch technology. This would mean you must set-up a user name and password to open confidential e-mail messages we send you. However, you can contact us (in writing or email) to ask us not to encrypt our reply. For more information on how you will be affected by our e-mail security arrangements please go to www.guildford.gov.uk/SecureEmail.

Guildford Borough Council UNCLASSIFIED INTERNAL